



Winston H. Hickox  
Agency Secretary

# Air Resources Board

Alan C. Lloyd, Ph.D.  
Chairman

2020 L Street • P.O. Box 2815 • Sacramento, California 95812 • [www.arb.ca.gov](http://www.arb.ca.gov)



Gray Davis  
Governor

April 21, 2000

Sergio M. Bravo  
President, CEO  
S. Bravo Systems, Inc.  
2929 Vail Avenue  
Commerce, CA 90040-2615


00-03

Dear Mr. Bravo:

## Approval of the Model B-75 Phase I Swivel Vapor Adapters

This is in response to your request for California Air Resources Board (CARB) approval of the Model B-75 A and Model B-75 B swivel vapor adapters for use with two point Phase I vapor recovery systems at gasoline dispensing facilities. The difference between the two models is the Model B-75 A is aluminum and the Model B-75 B is brass. The swivel feature prevents loosening of the unit from, or over-tightening onto, the vapor riser pipe, which can occur during the connection/disconnection procedure of the vapor return line.

The B-75 swivel vapor adapter assemblies, illustrated below, consists of a base and an adapter. The base is tightened to the riser pipe, with a tool such as the Bravo BT-70 (depicted below), and secured with setscrews. A gasket, which seats in the base, compresses to ensure that a tight seal is created with the lip of the riser pipe. When torque is applied by movement of the vapor hose and elbow, the adapter portion will rotate while the base remains in place.



Bravo B-75 Swivel Vapor Adapter



Sergio M. Bravo  
April 21, 2000  
Page 2

As required by the Certification Procedures for Gasoline Vapor Recovery Systems at Service Stations, the approval of the Department of Occupational Safety and Health agency is a precondition to certification by the Air Resources Board. The appropriate letter of approval has been received and is listed as follows:

Department of Occupational Safety and Health  
February 18, 2000

I find that the use of the Bravo B-75 swivel vapor adapters, when installed in accordance with the manufacturer's instructions and the conditions listed above, will not adversely affect the performance of vapor recovery systems on which it is installed. Therefore, the Bravo B-75 swivel vapor adapter is certified for use with CARB certified two point Phase I vapor recovery configurations.

If you have any questions or wish to discuss this matter further, please do not hesitate to telephone R. Neil Nipper at (916) 324-7343.

Sincerely,

*Signed copy on file*

James J. Morgester, Chief  
Compliance Division

Cc: Larry F. Green, CAPCOA  
Steward J. Wilson, CAPCOA  
Bill Dillon, SBAPCD  
David Schott, MBUAPCD  
Jim Johnston, MBUAPCD  
Terry Dutton, SDAPCD  
Isam Boulad, SMAQMD  
Leslie Krinsk, ARB

Jack Bean, BAAQMD  
Robert Kwong, BAAQMD  
Peter Mieras, SCAQMD  
Richard Sommerville, SDAPCD  
Barnard McEntire, SDAPCD